

WHAT CERTIFICATION EXAM SHOULD I TAKE?

Version 05/30/2024



Test	Description
AS-3(S)	Install, inspect, test, and maintain automatic sprinkler systems (including standpipes), State Level 3
AS-2(S)	Install, inspect, test, and maintain automatic sprinkler systems (including standpipes), State Level 2
AS-ITT(S)	Inspect and test (except "acceptance testing") water-based fire protection systems, State Level I & T
E-1	Install, inspect, test, and maintain foam and water mist fire extinguishing systems. Must also maintain NAFED engineered fire suppression systems, and AS-3 or AS-2 (supervised by a journey level sprinkler fitter) certification if installing piping. ¹ (NFPA 11, 750, 2010)
E-2	Install, inspect, test, and maintain carbon dioxide fire extinguishing systems. Must also maintain NAFED engineered fire suppression systems certification. ¹ (NFPA 12)
E-3 ²	Install, inspect, test, and maintain clean agent, halon replacement, engineered wet chemical, and dry chemical fire extinguishing systems, including spray booths. Must also maintain NAFED engineered fire suppression systems, and/or ICC/NAFED pre-engineered industrial fire extinguishing systems. Note: If a water-based fire protection system is used, then the AS-3 certification or AS-2 (supervised by a journey level sprinkler fitter) certification is required with the E-3. ¹ (NFPA 17, 17A, and 2001)
E-4 ²	Install, inspect, test, and maintain pre-engineered kitchen hood suppression systems. Must also maintain the appropriate ICC/NAFED pre-engineered kitchen fire extinguishing systems certification, and an AS-3 or AS-2 (supervised by a journey level sprinkler fitter) certification if installing fire-water piping. ¹ (NFPA 17A and NFPA 96)
EG-1	Install (non-electrical), inspect, test, and maintain emergency generators.
EG-ITM	Inspect, test (except "acceptance testing"), and maintain emergency generators.
FA-1	Install, program, inspect, test, and maintain automatic fire alarm systems in any building. Must also maintain a NICET II certification in fire alarm systems or ESA/NTS equivalent.
FA-ITM	Inspect, test (except "acceptance testing"), and maintain automatic fire alarm systems. Must also maintain a NICET II certification in inspection and testing of fire alarm systems or ESA/NTS equivalent.
FP-1	Install, inspect, test, and maintain fire pumps and controllers. Must also maintain an AS-3 or AS-2 (supervised by a journey level sprinkler fitter) certification if installing piping.
FP-ITM	Inspect, test (except "acceptance testing"), and maintain fire pumps and controllers.
FEX-1	All activities relating to portable fire extinguishers incl those listed in Types FEX-2, FEX-3, and FEX-4.
FEX-2	Install, inspect, test, maintain, charge, and recharge portable fire extinguishers.
FEX-3	Hydrostatic testing of fire extinguisher cylinders.
FEX-4	Annual external examination of CO2 or stored pressure fire extinguishers equipped with pressure indicators or gauges.
SC-1	Install, inspect, test, and maintain smoke control systems. Must also maintain an ANSI-accredited fire life safety 2 or smoke control technician certification per State requirements in RCW 19.27.720 1(b).
SC-ITM	Inspect, test (except "acceptance testing"), and maintain smoke control systems. Must also maintain an ANSI-accredited fire life safety 2 or smoke control technician certification per RCW 19.27.720 1(b).
STP-ITM	Inspect, test (except "acceptance testing"), and maintain standpipe systems. Must also maintain State Level I & T. Note: installation of standpipes requires an AS-2(S) or AS-3(S) certification as of 2015 for compliance with State law.
<p>¹ NICET Level II or higher in "special hazards supp systems" required in lieu of ICC/NAFED starting 1/1/2025.</p> <p>² For scope for E-3 and E-4 issued prior to 2024, contact SFD_FMO_Certification@seattle.gov. Scope is grandfathered in until cards' expiration date.</p>	